

2019 Bi-Weekly Sampling

<u>Date</u>	<u>Address</u>	<u>T.C.</u>	<u>E.C.</u>	<u>Free Ammonia</u>	Chlorine(mg/L)	
					<u>Free</u>	<u>Total</u>
January 2nd	Water Plant	0	0	0.01	0.99	1.07
	19 Briarfield Court	0	0		0.89	1.00
January 15th	Water Plant	0	0	0.00	0.75	0.85
	309 Bronstone Drive	0	0		0.55	0.61
January 29th	Water Plant	0	0	0.07	1.17	1.35
	1 Arena Road	0	0		1.03	1.13
February 13th	Water Plant	0	0	0.00	0.98	1.12
	309 Bronstone Drive	0	0		0.75	0.81
February 26th	Water Plant	0	0	0.00	1.07	1.25
	1 Arena Road	0	0		1.05	1.14
March 12th	Water Plant	0	0	0.02	0.76	0.88
	309 Bronstone Drive	0	0		0.73	0.78
March 26th	Water Plant	0	0	0.00	0.83	1.01
	39 Wyndham Court	0	0		0.77	0.90
April 9th	Water Plant	0	0	0.00	0.96	0.99
	18 Vista Cove	0	0		0.93	1.08
April 23rd	Water Plant	0	0	0.00	0.79	0.88
	19 Briarfield Court	0	0		0.29	0.32
May 7th	Water Plant	0	0	0.03	1.73	2.04
	605 Muirfield Cove	0	0		0.46	0.51
May 21st	Water Plant	0	0	0.04	1.20	1.32
	10 Andover Place	0	0		1.09	1.32
June 4th	Water Plant	0	0	0.04	1.07	1.22
	27 Vista Cove	0	0		1.05	1.22
June 18th	Water Plant	0	0	0.00	1.03	1.24
	109 Breckenridge Drive	0	0		1.04	1.16

July 2nd	Water Plant	0	0	0.00	0.92	1.02
	109 Saint Andrew's Way	0	0		0.72	0.87
July 16th	Water Plant	0	0	0.00	0.78	1.02
	119 Claremont Drive	0	0		0.87	0.99
July 30th	Water Plant	0	0	0.01	1.01	1.13
	25 Hampton Drive	0	0		1.00	1.11
August 13th	Water Plant	0	0	0.01	0.99	1.17
	26 Vista Cove	0	0		1.04	1.11
August 27th	Water Plant	0	0	0.04	0.97	1.11
	5 Briarfield Court	0	0		0.73	0.82
September 10th	Water Plant	0	0	0.05	0.73	0.81
	309 Bronstone Drive	0	0		0.84	0.90
September 24th	Water Plant	0	0	0.05	2.20	2.20
	Splash Pad	0	0		0.84	0.90
October 8th	Water Plant	0	0	0.03	0.96	1.17
	1 Arena Road	0	0		0.92	1.04
October 22nd	Water Plant	0	0	0.05	0.91	1.11
	329 Bronstone Drive	0	0		0.83	0.91
November 5th	Water Plant	0	0	0.00	0.82	0.97
	11 Briarfield Court	0	0		0.72	0.74
November 18th	Water Plant	0	0	0.04	0.76	0.93
	197 Saint Andrew's Way	0	0		0.51	0.54
December 3rd	Water Plant	0	0	0.00	0.83	1.02
	1 Arena Road	0	0		0.78	0.84
December 17th	Water Plant	0	0	0.00	0.81	0.99
	309 Bronstone Drive	0	0		0.77	0.89
December 31st	Water Plant	0	0	0.01	0.84	1.05
	329 Bronstone Drive	0	0		0.71	0.80