

## 2020 Bi-Weekly Sampling

<u>Date</u>	<u>Address</u>	<u>T.C.</u>	<u>E.C</u>	<u>Free</u>	<u>Chlorine (mg/L)</u>	
				<u>Ammonia</u>	<u>Free</u>	<u>Total</u>
January 14th	Raw Water	0	0		0.00	0.00
	Water Treatment Plant	0	0	0.00	0.74	0.91
	500 Prairie Trail	0	0		0.74	0.81
January 28th	Raw Water	0	0		0.00	0.00
	Water Treatment Plant	0	0	0.00	0.82	1.01
	203 Saint Andrew's Way	0	0		0.76	0.89
Febryuary 11th	Raw Water	0	0		0.00	0.00
	Water Treatment Plant	0	0	0.00	0.96	1.08
	15 Vist Cove	0	0		0.70	0.73
February 25th	Raw Water	0	0		0.00	0.00
	Water Treatmnet Plant	0	0	0.00	0.85	1.03
	103 Claremont Drive	0	0		0.70	0.73
March 10th	Raw Water	0	0		0.00	0.00
	Water Treatment Plant	0	0	0.00	0.81	0.94
	1 Arena Road	0	0		0.74	0.78
March 24th	Raw Water	0	0		0.00	0.00
	Water Treatment Plant	0	0	0.00	0.87	0.97
	21 Denby Cove	0	0		0.82	0.90
April 7th	Raw Water	0	0		0.00	0.00
	Water Treatment Plant	0	0	0.02	0.92	1.10
	55 Tweed Lane	0	0		0.88	1.04
April 21st	Raw Water	0	0		0.00	0.00
	Water Treatment Plant	0	0	0.00	0.84	1.03
	714 Birkdale Cove	0	0		0.64	0.78
May 5th	Raw Water	0	0		0.00	0.00
	Water Treatment Plant	0	0	0.00	0.76	0.94
	309 Bronstone Drive	0	0		0.74	0.82
May 20th	Raw Water	0	0		0.00	0.00
	Water Treatment Plant	0	0	0.00	0.77	0.96
	105 Breckenridge Drive	0	0		0.77	0.89
June 2nd	Raw Water	0	0		0.00	0.00

	Water Treatment Plant	0	0	0.01	0.80	0.99
	197 Saint Andrew's Way	0	0		0.83	0.96
June 16th	Raw Water	0	0		0.00	0.00
	Water Treatment Plant	0	0	0.00	0.92	1.09
	19 Briarfield Court	0	0		0.81	0.93
June 30th	Raw Water	0	0		0.00	0.00
	Water Treatment Plant	0	0	0.00	0.92	1.01
	309 Bronstone Drive	0	0		0.78	0.87
July 14th	Raw Water	0	0		0.00	0.00
	Water Treatment Plant	0	0	0.00	0.81	0.93
	17 Vista Cove	0	0		0.81	0.89
July 28th	Raw Water	1	1		0.00	0.00
	Water Treatment Plant	0	0	0.00	0.71	0.88
	500 Lytham Place	0	0		0.53	0.62
August 11th	Raw Water	0	0		0.00	0.00
	Water Treatment Plant	0	0	0.03	0.78	0.94
	24 Kipling Lane	0	0		0.75	0.85
August 25th	Raw Water	0	0		0.00	0.00
	Water Treatment Plant	0	0	0.00	0.74	0.90
	329 Bronstone Drive	0	0		0.67	0.80
September 8th	Raw Water	0	0		0.00	0.00
	Water Treatment Plant	0	0	0.00	0.83	0.96
	1 Arena Road	0	0		0.71	0.76
September 22nd	Raw Water	0	0		0.00	0.00
	Water Treatment Plant	0	0	0.00	0.76	0.87
	Splash Pad	0	0		0.59	0.76
October 6th	Raw Water	0	0		0.00	0.00
	Water Treatment Plant	0	0	0.00	0.87	1.07
	24 Aberdeen Drive	0	0		0.73	0.75
October 20th	Raw Water	0	0		0.00	0.00
	Water Treatment Plant	0	0	0.00	0.87	1.03
	26 Briarfield Court	0	0		0.78	0.82
November 3rd	Raw Water	0	0		0.00	0.00
	Water Treatment Plant	0	0	0.00	0.83	0.93
	25 Vista Cove	0	0		0.79	0.85

November 18th	Raw Water	0	0		0.00	0.00
	Water Treatment Plant	0	0	0.00	0.80	0.90
	309 Bronstone Drive	0	0		0.78	0.81
December 1st	Raw Water	0	0		0.00	0.00
	Water Treatment Plant	0	0	0.00	0.77	0.89
	29 Foxdale Way	0	0		0.79	0.90
December 15th	Raw Water	0	0		0.00	0.00
	Water Treatment Plant	0	0	0.01	0.75	0.84
	1 Arena Road	0	0		0.71	0.77
December 29th	Raw Water	0	0		0.00	0.00
	Water Treatment Plant	0	0	0.00	1.00	1.14
	714 Birkdale Cove	0	0		0.67	0.86