



Town of Niverville - Spruce Drive Water  
Plant  
ATTN: RYAN DYCK  
Niverville Spruce Drive - PWS  
Box 267  
Niverville MB R0A 1E0

Date Received: 23-FEB-21  
Report Date: 04-MAR-21 10:54 (MT)  
Version: FINAL

Client Phone: 204-388-4600

## Certificate of Analysis

Lab Work Order #: L2560019  
Project P.O. #: NOT SUBMITTED  
Job Reference: NIVERVILLE SPRUCE DRIVE - PWS - 151.25  
C of C Numbers:  
Legal Site Desc: 42862

Hua Wo  
Chemistry Laboratory Manager

[This report shall not be reproduced except in full without the written authority of the Laboratory.]

ADDRESS: 1329 Niakwa Road East, Unit 12, Winnipeg, MB R2J 3T4 Canada | Phone: +1 204 255 9720 | Fax: +1 204 255 9721  
ALS CANADA LTD Part of the ALS Group An ALS Limited Company

# ANALYTICAL REPORT

## Physical Tests (WATER)

		ALS ID		L2560019-1	L2560019-2
		Sampled Date		23-FEB-21	23-FEB-21
		Sampled Time		07:47	07:40
		Sample ID		<b>NIVERVILLE SPRUCE DRIVE 1 - RAW</b>	<b>NIVERVILLE SPRUCE DRIVE 2 - TREATED</b>
Analyte	Unit	Guide Limit #1	Guide Limit #2		
Colour, True	CU	15	-	<5.0	<5.0
Conductivity	umhos/cm	-	-	1220	305
Hardness (as CaCO3)	mg/L	-	-	175 <sup>HTC</sup>	28.7 <sup>HTC</sup>
Langelier Index (4 C)	No Unit	-	-	0.31	-1.2
Langelier Index (60 C)	No Unit	-	-	1.1	-0.40
pH	pH units	7.00-10.5	-	8.05	7.84
Total Dissolved Solids	mg/L	500	-	628	156
Transmittance, UV (254 nm)	%T/cm	-	-	92.3	96.2
Turbidity	NTU	-	-	2.88	<0.10

### Federal Guidelines for Canadian Drinking Water Quality (JAN, 2021)

#1: GCDWQ - Aesthetic Objective/Other Value (Jan.2020)

#2: GCDWQ - Maximum Acceptable Concentrations (MACs-Jan.2020)

## Anions and Nutrients (WATER)

		ALS ID		L2560019-1	L2560019-2
		Sampled Date		23-FEB-21	23-FEB-21
		Sampled Time		07:47	07:40
		Sample ID		<b>NIVERVILLE SPRUCE DRIVE 1 - RAW</b>	<b>NIVERVILLE SPRUCE DRIVE 2 - TREATED</b>
Analyte	Unit	Guide Limit #1	Guide Limit #2		
Alkalinity, Total (as CaCO3)	mg/L	-	-	277	65.8
Ammonia, Total (as N)	mg/L	-	-	0.65	<0.010
Bicarbonate (HCO3)	mg/L	-	-	338	80.3
Bromide (Br)	mg/L	-	-	0.208	<0.010
Carbonate (CO3)	mg/L	-	-	<0.60	<0.60
Chloride (Cl)	mg/L	250	-	199	48.6
Fluoride (F)	mg/L	-	1.5	0.883	0.196
Hydroxide (OH)	mg/L	-	-	<0.34	<0.34
Nitrate (as N)	mg/L	-	10	<0.0050	0.0066
Nitrite (as N)	mg/L	-	1	<0.0010	<0.0010
Sulfate (SO4)	mg/L	500	-	35.3	5.92

### Federal Guidelines for Canadian Drinking Water Quality (JAN, 2021)

#1: GCDWQ - Aesthetic Objective/Other Value (Jan.2020)

#2: GCDWQ - Maximum Acceptable Concentrations (MACs-Jan.2020)

## Organic / Inorganic Carbon (WATER)

		ALS ID		L2560019-1	L2560019-2
		Sampled Date		23-FEB-21	23-FEB-21
		Sampled Time		07:47	07:40
		Sample ID		<b>NIVERVILLE SPRUCE DRIVE 1 - RAW</b>	<b>NIVERVILLE SPRUCE DRIVE 2 - TREATED</b>
Analyte	Unit	Guide Limit #1	Guide Limit #2		
Dissolved Organic Carbon	mg/L	-	-	1.84	<0.50
Total Organic Carbon	mg/L	-	-	1.73	<0.50

### Federal Guidelines for Canadian Drinking Water Quality (JAN, 2021)

#1: GCDWQ - Aesthetic Objective/Other Value (Jan.2020)

#2: GCDWQ - Maximum Acceptable Concentrations (MACs-Jan.2020)

Detection Limit for result exceeds Guide Limit. Assessment against Guide Limit cannot be made.

Analytical result for this parameter exceeds Guide Limit listed on this report.

\* Please refer to the Reference Information section for an explanation of any qualifiers noted.

**Total Metals (WATER)**

Analyte	Unit	ALS ID		L2560019-1	L2560019-2
		Guide Limit #1	Guide Limit #2	Sampled Date Sampled Time Sample ID	Sampled Date Sampled Time Sample ID
Aluminum (Al)-Total	mg/L	0.1	-	<0.0030	<0.0030
Antimony (Sb)-Total	mg/L	-	0.006	<0.00010	<0.00010
Arsenic (As)-Total	mg/L	-	0.01	0.00378	0.00162
Barium (Ba)-Total	mg/L	-	2	0.0542	0.00932
Beryllium (Be)-Total	mg/L	-	-	<0.00010	<0.00010
Bismuth (Bi)-Total	mg/L	-	-	<0.000050	<0.000050
Boron (B)-Total	mg/L	-	5	0.532	0.260
Cadmium (Cd)-Total	mg/L	-	0.005	<0.0000050	<0.0000050
Calcium (Ca)-Total	mg/L	-	-	35.6	6.03
Cesium (Cs)-Total	mg/L	-	-	<0.000010	<0.000010
Chromium (Cr)-Total	mg/L	-	0.05	<0.00010	<0.00010
Cobalt (Co)-Total	mg/L	-	-	0.00012	<0.00010
Copper (Cu)-Total	mg/L	1	2	0.00098	0.0186
Iron (Fe)-Total	mg/L	0.3	-	0.459	0.066
Lead (Pb)-Total	mg/L	-	0.005	0.000371	<0.000050
Lithium (Li)-Total	mg/L	-	-	0.0590	0.0117
Magnesium (Mg)-Total	mg/L	-	-	20.9	3.31
Manganese (Mn)-Total	mg/L	0.02	0.12	0.00626	0.00112
Molybdenum (Mo)-Total	mg/L	-	-	0.00396	0.000639
Nickel (Ni)-Total	mg/L	-	-	0.00051	0.00082
Phosphorus (P)-Total	mg/L	-	-	<0.050	0.120
Potassium (K)-Total	mg/L	-	-	10.5	2.20
Rubidium (Rb)-Total	mg/L	-	-	0.00518	0.00106
Selenium (Se)-Total	mg/L	-	0.05	<0.000050	<0.000050
Silicon (Si)-Total	mg/L	-	-	5.27	1.04
Silver (Ag)-Total	mg/L	-	-	<0.000010	<0.000010
Sodium (Na)-Total	mg/L	200	-	208	49.4
Strontium (Sr)-Total	mg/L	-	7	0.514	0.0896
Tellurium (Te)-Total	mg/L	-	-	<0.00020	<0.00020
Thallium (Tl)-Total	mg/L	-	-	<0.000010	<0.000010
Thorium (Th)-Total	mg/L	-	-	<0.00010	<0.00010
Tin (Sn)-Total	mg/L	-	-	<0.00010	<0.00010
Titanium (Ti)-Total	mg/L	-	-	<0.00030	<0.00030

**Federal Guidelines for Canadian Drinking Water Quality (JAN, 2021)**

**#1: GCDWQ - Aesthetic Objective/Other Value (Jan.2020)**

**#2: GCDWQ - Maximum Acceptable Concentrations (MACs-Jan.2020)**

Detection Limit for result exceeds Guide Limit. Assessment against Guide Limit cannot be made.

Analytical result for this parameter exceeds Guide Limit listed on this report.

\* Please refer to the Reference Information section for an explanation of any qualifiers noted.

# ANALYTICAL REPORT

## Total Metals (WATER)

		ALS ID		L2560019-1	L2560019-2
		Sampled Date		23-FEB-21	23-FEB-21
		Sampled Time		07:47	07:40
		Sample ID		<b>NIVERVILLE</b>	<b>NIVERVILLE</b>
Analyte	Unit	Guide Limit #1	Guide Limit #2	<b>SPRUCE DRIVE 1 - RAW</b>	<b>SPRUCE DRIVE 2 - TREATED</b>
Tungsten (W)-Total	mg/L	-	-	<0.00010	<0.00010
Uranium (U)-Total	mg/L	-	0.02	0.000249	0.000039
Vanadium (V)-Total	mg/L	-	-	<0.00050	<0.00050
Zinc (Zn)-Total	mg/L	5	-	0.0058	0.0135
Zirconium (Zr)-Total	mg/L	-	-	<0.00020	<0.00020

**Federal Guidelines for Canadian Drinking Water Quality (JAN, 2021)**

**#1: GCDWQ - Aesthetic Objective/Other Value (Jan.2020)**

**#2: GCDWQ - Maximum Acceptable Concentrations (MACs-Jan.2020)**

## Volatile Organic Compounds (WATER)

		ALS ID		L2560019-1
		Sampled Date		23-FEB-21
		Sampled Time		07:47
		Sample ID		<b>NIVERVILLE</b>
Analyte	Unit	Guide Limit #1	Guide Limit #2	<b>SPRUCE DRIVE 1 - RAW</b>
Benzene	mg/L	-	0.005	<0.00050
1,1-dichloroethene	mg/L	-	0.014	<0.00050
Dichloromethane	mg/L	-	0.05	<0.00050
Ethylbenzene	mg/L	0.0016	0.14	<0.00050
MTBE	mg/L	0.015	-	<0.00050
Tetrachloroethene	mg/L	-	0.01	<0.00050
Toluene	mg/L	0.024	0.06	<0.00050
Trichloroethene	mg/L	-	0.005	<0.00050
o-Xylene	mg/L	-	-	<0.00050
M+P-Xylenes	mg/L	-	-	<0.00040
Xylenes (Total)	mg/L	0.02	0.09	<0.00064
Surrogate: 4-Bromofluorobenzene (SS)	%	-	-	94.3
Surrogate: 1,4-Difluorobenzene (SS) %		-	-	99.7

**Federal Guidelines for Canadian Drinking Water Quality (JAN, 2021)**

**#1: GCDWQ - Aesthetic Objective/Other Value (Jan.2020)**

**#2: GCDWQ - Maximum Acceptable Concentrations (MACs-Jan.2020)**

Detection Limit for result exceeds Guide Limit. Assessment against Guide Limit cannot be made.

Analytical result for this parameter exceeds Guide Limit listed on this report.

\* Please refer to the Reference Information section for an explanation of any qualifiers noted.

## Reference Information

**Qualifiers for Individual Parameters Listed:**

Qualifier	Description
HTC	Hardness was calculated from Total Ca and/or Mg concentrations and may be biased high (dissolved Ca/Mg results unavailable).

**Methods Listed (if applicable):**

ALS Test Code	Matrix	Test Description	Method Reference**
<b>ALK-CO3CO3-CALC-WP</b>	Water	Alkalinity, Carbonate	CALCULATION
The Alkalinity of water is a measure of its acid neutralizing capacity. Alkalinity is imparted by bicarbonate, carbonate and hydroxide components of water. The fraction of alkalinity contributed by carbonate is calculated and reported as mg CO <sub>3</sub> 2-/L.			
<b>ALK-HCO3HCO3-CALC-WP</b>	Water	Alkalinity, Bicarbonate	CALCULATION
The Alkalinity of water is a measure of its acid neutralizing capacity. Alkalinity is imparted by bicarbonate, carbonate and hydroxide components of water. The fraction of alkalinity contributed by bicarbonate is calculated and reported as mg HCO <sub>3</sub> -/L.			
<b>ALK-OHOH-CALC-WP</b>	Water	Alkalinity, Hydroxide	CALCULATION
The Alkalinity of water is a measure of its acid neutralizing capacity. Alkalinity is imparted by bicarbonate, carbonate and hydroxide components of water. The fraction of alkalinity contributed by hydroxide is calculated and reported as mg OH-/L.			
<b>ALK-TITR-WP</b>	Water	Alkalinity, Total (as CaCO <sub>3</sub> )	APHA 2320B
The Alkalinity of water is a measure of its acid neutralizing capacity. Alkalinity is imparted by bicarbonate, carbonate and hydroxide components of water. Total alkalinity is determined by titration with a strong standard mineral acid to the successive HCO <sub>3</sub> - and H <sub>2</sub> CO <sub>3</sub> endpoints indicated electrometrically.			
<b>BR-L-IC-N-WP</b>	Water	Bromide in Water by IC (Low Level)	EPA 300.1 (mod)-LR
Inorganic anions are analyzed by Ion Chromatography with conductivity and/or UV detection.			
<b>C-DOC-HTC-WP</b>	Water	Dissolved Organic Carbon by Combustion	APHA 5310 B-WP
Filtered (0.45 um) sample is acidified and purged to remove inorganic carbon, then injected into a heated reaction chamber where organic carbon is oxidized to CO <sub>2</sub> which is then transported in the carrier gas stream and measured via a non-dispersive infrared analyzer.			
<b>C-TOC-HTC-WP</b>	Water	Total Organic Carbon by Combustion	APHA 5310 B-WP
Sample is acidified and purged to remove inorganic carbon, then injected into a heated reaction chamber where organic carbon is oxidized to CO <sub>2</sub> which is then transported in the carrier gas stream and measured via a non-dispersive infrared analyzer.			
<b>CL-L-IC-N-WP</b>	Water	Chloride in Water by IC (Low Level)	EPA 300.1 (mod)
Inorganic anions are analyzed by Ion Chromatography with conductivity and/or UV detection.			
<b>COLOUR-TRUE-WP</b>	Water	Colour, True	APHA 2120C
True Colour is measured spectrophotometrically by comparison to platinum-cobalt standards using the single wavelength method (450 - 465 nm) after filtration of sample through a 0.45 um filter. Colour measurements can be highly pH dependent, and apply to the pH of the sample as received (at time of testing), without pH adjustment. Concurrent measurement of sample pH is recommended.			
<b>EC-SCREEN-WP</b>	Water	Conductivity Screen (Internal Use Only)	APHA 2510
Qualitative analysis of conductivity where required during preparation of other test eg. IC, TDS, TSS, etc			
<b>EC-WP</b>	Water	Conductivity	APHA 2510B
Conductivity of an aqueous solution refers to its ability to carry an electric current. Conductance of a solution is measured between two spatially fixed and chemically inert electrodes.			
<b>ETL-LANGELIER-4-WP</b>	Water	Langelier Index 4C	Calculated
<b>ETL-LANGELIER-60-WP</b>	Water	Langelier Index 60C	Calculated
<b>F-IC-N-WP</b>	Water	Fluoride in Water by IC	EPA 300.1 (mod)
Inorganic anions are analyzed by Ion Chromatography with conductivity and/or UV detection.			
<b>HARDNESS-CALC-WP</b>	Water	Hardness Calculated	APHA 2340B
Hardness (also known as Total Hardness) is calculated from the sum of Calcium and Magnesium concentrations, expressed in CaCO <sub>3</sub> equivalents. Dissolved Calcium and Magnesium concentrations are preferentially used for the hardness calculation.			
<b>IONBALANCE-CALC-WP</b>	Water	Ion Balance Calculation	APHA 1030E

## Reference Information

**Methods Listed (if applicable):**

ALS Test Code	Matrix	Test Description	Method Reference**
---------------	--------	------------------	--------------------

Cation Sum, Anion Sum, and Ion Balance (as % difference) are calculated based on guidance from APHA Standard Methods (1030E Checking Correctness of Analysis). Because all aqueous solutions are electrically neutral, the calculated ion balance (% difference of cations minus anions) should be near-zero.

Cation and Anion Sums are the total meq/L concentration of major cations and anions. Dissolved species are used where available. Minor ions are included where data is present. Ion Balance (as % difference) cannot be calculated accurately for waters with very low electrical conductivity (EC), and is reported as "Low EC" where EC < 100 uS/cm (umhos/cm). Ion Balance is calculated as:

$$\text{Ion Balance (\%)} = [\text{Cation Sum} - \text{Anion Sum}] / [\text{Cation Sum} + \text{Anion Sum}]$$

**MET-T-CCMS-WP** Water Total Metals in Water by CRC ICPMS EPA 200.2/6020B (mod.)

Water samples are digested with nitric and hydrochloric acids, and analyzed by CRC ICPMS.

Method Limitation (re: Sulfur): Sulfide and volatile sulfur species may not be recovered by this method.

**NH3-COL-WP** Water Ammonia by colour APHA 4500 NH3 F

Ammonia in water samples forms indophenol when reacted with hypochlorite and phenol. The intensity is amplified by the addition of sodium nitroprusside and measured colourmetrically.

**NO2-L-IC-N-WP** Water Nitrite in Water by IC (Low Level) EPA 300.1 (mod)

Inorganic anions are analyzed by Ion Chromatography with conductivity and/or UV detection.

**NO3-L-IC-N-WP** Water Nitrate in Water by IC (Low Level) EPA 300.1 (mod)

Inorganic anions are analyzed by Ion Chromatography with conductivity and/or UV detection.

**PH-WP** Water pH APHA 4500H

The pH of a sample is the determination of the activity of the hydrogen ions by potentiometric measurement using a standard hydrogen electrode and a reference electrode.

**SO4-IC-N-WP** Water Sulfate in Water by IC EPA 300.1 (mod)

Inorganic anions are analyzed by Ion Chromatography with conductivity and/or UV detection.

**TDS-WP** Water Total Dissolved Solids (TDS) APHA 2540 SOLIDS C,E

A well-mixed sample is filtered through a glass fiber filter paper. The filtrate is then evaporated to dryness in a pre-weighed vial and dried at 180 – 2C. The increase in vial weight represents the total dissolved solids.

**TURBIDITY-WP** Water Turbidity APHA 2130B (modified)

Turbidity in aqueous matrices is determined by the nephelometric method.

**UV-%TRANS-WP** Water UV Transmittance (Calculated) APHA 5910B

Test method is adapted from APHA Method 5910B. A sample is filtered through a 0.45 um polyethersulfone (PES) filter and its UV Absorbance is measured in a quartz cell at 254 nm. UV Transmittance is calculated from the UV Absorbance result and reported as UV Transmittance per cm. The analysis is carried out without pH adjustment.

**VOC+F1-HSMS-WP** Water VOC plus F1 by GCMS EPA 8260C / EPA 5021A

In this method samples are analyzed using a headspace autosampler interfaced to a dual column gas chromatograph with MS and Flame Ionization detectors.

**XYLENES-SUM-CALC-WP** Water Sum of Xylene Isomer Concentrations CALCULATED RESULT

Total xylenes represents the sum of o-xylene and m&p-xylene.

\*\*ALS test methods may incorporate modifications from specified reference methods to improve performance.

Chain of Custody Numbers:

*The last two letters of the above test code(s) indicate the laboratory that performed analytical analysis for that test. Refer to the list below:*

Laboratory Definition Code Laboratory Location

WP ALS ENVIRONMENTAL - WINNIPEG, MANITOBA, CANADA

## Reference Information

### GLOSSARY OF REPORT TERMS

*Surrogates are compounds that are similar in behaviour to target analyte(s), but that do not normally occur in environmental samples. For applicable tests, surrogates are added to samples prior to analysis as a check on recovery. In reports that display the D.L. column, laboratory objectives for surrogates are listed there.*

*mg/kg - milligrams per kilogram based on dry weight of sample*

*mg/kg wwt - milligrams per kilogram based on wet weight of sample*

*mg/kg lwt - milligrams per kilogram based on lipid-adjusted weight*

*mg/L - unit of concentration based on volume, parts per million.*

*< - Less than.*

*D.L. - The reporting limit.*

*N/A - Result not available. Refer to qualifier code and definition for explanation.*

*Test results reported relate only to the samples as received by the laboratory.*

*UNLESS OTHERWISE STATED, ALL SAMPLES WERE RECEIVED IN ACCEPTABLE CONDITION.*

*Analytical results in unsigned test reports with the DRAFT watermark are subject to change, pending final QC review.*

*Application of guidelines is provided "as is" without warranty of any kind, either expressed or implied, including, but not limited to, fitness for a particular purpose, or non-infringement. ALS assumes no responsibility for errors or omissions in the information. Guideline limits are not adjusted for the hardness, pH or temperature of the sample (the most conservative values are used). Measurement uncertainty is not applied to test results prior to comparison with specified criteria values.*

**Manitoba**

Conservation and Climate  
Office of Drinking Water  
1007 Century Street, Winnipeg, Manitoba,  
Canada R3H 0W4



L2560019-COFC

Regular Service (default):

 Regular Service  
(is 5-7 Days):

Unless otherwise requested

 1 Day, rush / priority  
 2 Day, rush / priority  
 3 Day, rush / priority
**Report to Operator (email PDF):**

Contact: Ryan Dyck  
Address: Box 267, Niverville, MB R0A1E0  
Phone: (204) 388-4600  
Email: ryan@whereyoubelong.ca;  
operations@whereyoubelong.ca

**Report to Owner (email PDF):**

Contact: Eric King  
Address: Box 267, Niverville, MB R0A1E0  
Phone: (204) 388-4600  
Email: cao@whereyoubelong.ca

**Email PDF copy to:**

DWO: Sarah Belisle  
DWO Address: Unit B-284 Reimer Ave., Steinbach, MB R5G  
DWO Phone: (204) 371-5065  
DWO Email: Sarah.Belisle@gov.mb.ca  
Additional Email: Joern.Muenster@gov.mb.ca;  
Nancy.Eidse@gov.mb.ca

**If an update in Owner or Operator contact information is required, please contact your Drinking Water Officer**

<b>Client / Project Information:</b>	<b>Lab:</b>	<b>Account:</b>	<b>Agency Code:</b> 382	<b>Report Type:</b> EMS (Lab-MWS)	<b>Project:</b> DWQ-C
<b>Operation Name:</b>	NIVERVILLE SPRUCE DRIVE - PWS		<b>Expected Sample Time:</b>	February 23, 2021	
<b>Operation Code:</b>	151.25				
<b>Operation ID:</b>	42862				
<b>Sampled by:</b>	Andrew Rempel				

Please record Free & Total Chlorine residuals for Distribution By-product Sampling

**DO NOT COPY or RE-USE this form. Sample Number are unique to the Office of Drinking Water and provided by Drinking Water Officer.**

Sample Number	Station Number	Sample Identification	Free Chlorine (mg/L)	Total Chlorine (mg/L)	Sample Date dd-mmm-yyyy	Sample Time hh:mm	Sample Matrix	Sample Type	MB-CH-PWS-V2013	MB-VOC-PWS-V2013	# of Containers
2108SB5008	MB05OED101	Niverville Spruce Drive 1 - Raw	0.00	0.00	23-Feb-21	7:47am	6	1	X	X	7
2108SB5009	MB05OED102	Niverville Spruce Drive 2 - Treated	0.94	1.19	23-Feb-21	7:40am	10	1	X		4

Failure to complete all portions of this form may delay analysis.

Sample Matrix: 6-Raw Water, 9-Distributed Water, 10-Treated Water

Please fill in this form LEGIBLY.

Sample Type: 1-Grab Sample

By the use of this form the user acknowledges and agrees with the Terms and Conditions as specified by the Laboratory.

For ALL other testing, please use Laboratory specific forms.

<b>Relinquished By:</b>		<b>Date &amp; Time</b>		<b>Validated By (lab use only):</b>	APZ	<b>Date &amp; Time:</b>	
<b>Received By:</b> (lab use only)	APZ	<b>Date &amp; Time:</b> (lab use only)	23 Feb 11am	<b>Temperature</b>	8.3	<b>Samples Received in Good Condition?</b>	Y/N