

## 2021 Bi-Weekly Sampling

<u>Date</u>	<u>Address</u>	<u>T.C.</u>	<u>E.C</u>	<u>Free Ammonia</u>	<u>Chlorine (mg/L)</u>	
					<u>Free</u>	<u>Total</u>
January 12th	Raw Water	0	0		0.00	0.00
	Water Treatment Plant	0	0	0.00	0.67	0.80
	121 Breckenridge Drive	0	0		0.62	0.71
January 26th	Raw Water	0	0		0.00	0.00
	Water Treatment Plant	0	0	0.01	0.86	0.94
	329 Bronstone Drive	0	0		0.83	0.90
February 10th	Raw Water	0	0		0.00	0.00
	Water Treatment Plant	0	0	0.00	0.51	0.58
	1 Arena Road	0	0		0.28	0.31
February 23rd	Raw Water	0	0		0.00	0.00
	Water Treatment Plant	0	0	0.00	0.94	1.19
	31 Hawthorne Way	0	0		0.65	0.73
March 9th	Raw Water	0	0		0.00	0.00
	Water Treatment Plant	0	0	0.00	0.78	1.01
	309 Bronstone Drive	0	0		0.66	0.78
March 24th	Raw Water	>200	0		0.00	0.00
	Water Treatment Plant	0	0	0.00	0.80	0.94
	22 Claremont Drive	0	0		0.79	0.85
April 6th	Raw Water	0	0		0.00	0.00
	Water Treatment Plant	0	0	0.00	0.59	0.69
	193 Saint Andrew's Way	0	0		0.13	0.17
April 20th	Raw Water	0	0		0.00	0.00

	Water Treatment Plant	0	0	0.00	1.04	1.24
	22 Alders Gate	0	0		1.06	1.21
May 4th	Raw Water	0	0		0.00	0.00
	Water Treatment Plant	0	0	0.00	0.93	1.07
	32 Cobblestone Court	0	0		0.93	1.14
May 18th	Raw Water	0	0		0.00	0.00
	Water Treatment Plant	0	0	0.00	0.73	0.88
	49 Aberdeen Drive	0	0		0.54	0.63
June 1st	Raw Water	0	0		0.00	0.00
	Water Treatment Plant	0	0	0.00	0.73	0.93
	309 Bronstone Drive	0	0		0.78	0.88
June 15th	Raw Water	0	0		0.00	0.00
	Water Treatment Plant	0	0	0.00	0.90	1.09
	1 Arena Road	0	0		0.89	0.98
June 29th	Raw Water	5	5		0.00	0.00
	Water Treatment Plant	0	0	0.00	0.84	0.98
	100 Claremont Drive	0	0		0.83	0.94
July 13th	Raw Water	0	0		0.00	0.00
	Water Treatment Plant	0	0	0.02	0.80	0.97
	717 Birkdale Cove	0	0		0.49	0.57
July 27th	Raw Water	0	0		0.00	0.00
	Water Treatment Plant	0	0	0.00	0.87	1.07
	49 Aberdeen Drive	0	0		0.82	0.94
August 10th	Raw Water	0	0		0.00	0.00
	Water Treatment Plant	0	0	0.00	0.74	0.95
	Splash Pad	0	0		0.74	0.84

August 24th	Raw Water	0	0		0.00	0.00
	Water Treatment Plant	0	0		0.79	0.93
	1 Arena Road	0	0		0.76	0.85
September 7th	Raw Water	0	0		0.00	0.00
	Water Treatment Plant	0	0	0.01	0.80	1.00
	329 Bronstone Drive	0	0		0.65	0.67
September 21st	Raw Water	0	0		0.00	0.00
	Water Treatment Plant	0	0	0.00	0.94	1.12
	17 Vista Cove	0	0		0.86	1.00
October 5th	Raw Water	0	0		0.00	0.00
	Water Treatment Plant	0	0	0.00	0.81	0.97
	309 Bronstone Drive	0	0		0.55	0.62
October 19th	Raw Water	0	0		0.00	0.00
	Water Treatment Plant	0	0	0.00	0.76	0.95
	1 Arena Road	0	0		0.69	0.75
November 2nd	Raw Water	0	0		0.00	0.00
	Water Treatment Plant	0	0	0.00	0.84	1.05
	505 Lytham Place	0	0		0.64	0.74
November 16th	Raw Water	0	0			
	Water Treatment Plant	0	0	0.01	0.70	0.77
	329 Bronstone Drive	0	0		0.72	0.78
November 30th	Raw Water	0	0		0.00	0.00
	Water Treatment Plant	0	0	0.00	0.66	0.91
	160 Breckenridge Drive	0	0		0.64	0.71
December 14th	Raw Water	0	0		0.00	0.00

December 29th	Water Treatment Plant	0	0	0.00	0.89	1.05
	329 Bronstone Drive	0	0		0.95	1.05
	Raw Water	0	0		0.00	0.00
	Water Treatment Plant	0	0	0.00	0.90	1.02
	1 Arena Road	0	0		0.75	0.80